

Certificate

Registration No.: PV 50213712

Page 1

Report No.: 15040048.003

License Holder:

Worldwide Energy and Manufacturing USA,
Co., LIMITED
RM 1708 C1, NAN FUNG TOWER, 173 DES
VOEUX RD CENTRAL
HongKong

Product:

PV Module Types;

AS-6M-xxxW(xxx=260-315, in steps of 5, 72 cells)
AS-6M30-xxxW(xxx=215-260, in steps of 5, 60 cells)
AS-6M27-xxxW(xxx=195-235, in steps of 5, 54 cells)
AS-6M18-xxxW(xxx=130-155, in steps of 5, 36 cells)
AS-6P-xxxW(xxx=255-310, in steps of 5, 72 cells)
AS-6P30-xxxW(xxx=210-255, in steps of 5, 60 cells)
AS-6P27-xxxW(xxx=190-230, in steps of 5, 54 cells)
AS-6P18-xxxW(xxx=125-155, in steps of 5, 36 cells)
AS-5M-xxxW(xxx=170-205, in steps of 5, 72 cells)
AS-5M18-xxxW(xxx=085-100, in steps of 5, 36 cells)

Manufacturing Plant:

0001-15040048.001

Basis:

- IEC 61730-1:2004
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety
qualification"

- Factory Inspection**
To document the consistent quality of
the product factory inspections are
performed periodically.



- **Qualified, IEC 61215**
- **Safety tested,
IEC 61730**
- **Periodic inspection**

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants
at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The fire test (IEC 61730-2 / MST 23) was not performed.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or
processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 21 March 2016.

Shanghai, 29 September 2011

Certification body

Dipl.-Ing. Bernd Scheifer